



NOTES:

1. All dimensions in millimetres.
2. Contactor to be MOELLER 63A Z-SCH230/63-40 or equal equivalent.
3. Door Interlocked Isolator to be MOELLER 100A P3 - 100 / V / SVB or equal equivalent.
4. 0.7m long, 25mm² Double Insulated tails c/w 16mm² G/Y Earth cable to be provided for connection to L.V. Supply Point. Cables to exit panel on the right side through stuffing gland.
5. Fuses to be raised up through panel door with Polycarbonate inspection hatch.
6. All contained within an IP65 steel enclosure protected with polyester epoxy resin grey paint to RAL 7032 textured size 500mm high x 400mm wide x 150mm deep.

Rev	Amendment	Date
-----	-----------	------